

I/G Panel Ring Panel O/G Panel for TR O/G Panel








Note:
1、SF6 box material: 304 stainless steel;
2、Manual operation of C type cabinet, manual operation of V type cabinet with DC24V release;
3、RAL7035;

For and on behalf of
SMART ELECTRICAL ENGINEERING CO.,LTD.

Authorized Signature(s)

新沂市五联电气科技有限公司 SMART ELECTRICAL ENGINEERING Co.,Ltd	版本 Version	T0	图纸名称 Drawing Title	Layout	绘图 Drawn	W.T
	文件编号 Document Number	WL-M/N-DQ2101	项目名称 Project Name		审核 Checked	M.K
	单位 Unit	mm	产品型号 Product Model	12kV-CCCVC	核准 Approval	Sim.xu
	绘制日期 Drawing Date	30/July/2026	工程图号 Drawing Number		比例 Scale	1:1
电话 TEL ：+86 15951977801	URL www.wuliansee.com	邮箱 Mail ：olivia@wuliansee.com		MB版本	V02.2106	Pagination 1

Busbar:630A										
Un:12kV										
System chart										
S.N	1H1		1H2		1H3		1H4		1H5	
Function	I/C		0/G		0/G		for TR		Ring Unit	
Type	12/C		12/C		12/C		12/V		12/C	
Dimension	325*750*1600		325*750*1600		325*750*1600		325*750*1600		325*750*1600	
Name	Type	Qty	Type	Qty	Type	Qty	Type	Qty	Type	Qty
Gas-insulated Switchgear Load Switch	FLN-12(C)/630A-25KA three position	1	FLN-12(C)/630A-25KA three position	1	FLN-12(C)/630A-25KA three position	1			FLN-12(C)/630A-25KA three position	1
Circuit Breaker for Gas-insulated Switchgear							ZN-12(V)/630A-25KA With Disconnector\P Three-position	1		
Operatig Mechanism	Manual C-type Mechanism	1	Manual C-type Mechanism	1	Manual C-type Mechanism	1		1	Manual C-type Mechanism	1
Gas meter		1								
CTs							LMZK-10 0.5/10P10	3		
Self-powered Integrated Protection Relay							ZY100 CT	1		
Voltage indicator	DXN8D-Q AC225V 25PF	1	DXN8D-T	1	DXN8D-T	1	DXN8D-T	1	DXN8D-T	1
Electromagnetic Lock	DSN-AMY AC225V	1								
Front Cable Connector	JB-15/630A	3	JB-15/630A	3	JB-15/630A	3	JB-15/630A	3	JB-15/630A	3
Rear-connected Surge Arrester	HBLQ-17/45	3	HBLQ-17/45	3	HBLQ-17/45	3	HBLQ-17/45	3	HBLQ-17/45	3

For and on behalf of
SMART ELECTRICAL ENGINEERING CO.,LTD.

Authorized Signature(s)

Note:
1. SF6 gas-insulated switchgear;
2. Cable in/out from bottom;
3. Manual component operation;

新沂市五联电气科技有限公司

SMART ELECTRICAL ENGINEERING Co.,Ltd

电话 TEL : +86 15951977801 | 网址 URL : www.wuliansee.com | 邮箱 Mail : olivia@wuliansee.com

版本 Version	T0	图纸名称 Drawing Title	system drawing	绘图 Drawn	W.T
文件编号 Document Number	WL-M/N-DQ2101	项目名称 Project Name		审核 Checked	M.K
单位 Unit	mm	产品型号 Product Model	12kV-CCCVC	核准 Approval	Sim.xu
绘制日期 Drawing Date	31/July/2026	工程图号 Drawing Number		比例 Scale	1:1
MB版本	V02.2106			Pagination	1